

Shenandoah County Department of Fire and Rescue



Dry Hydrant Manual

Shenandoah County Department of Fire and Rescue Dry Hydrant Manual – Table of Contents

Toms Brook Vol. Fire Department Co. 9 Dry Hydrants	Page 3
Woodstock Fire Department Co. 12 Dry Hydrants	Page 7
Conicville Vol. Fire Department Co. 13 Dry Hydrants	Page 17
Ft. Valley Fire Department Co. 14 Dry Hydrants	Page 31
Orkney Spring Fire and Rescue Co. 18 Dry Hydrants	Page 50
New Market Fire and Rescue Co. 23 Dry Hydrants	Page 56
Strasburg Fire Department Co. 51 Dry Hydrants	Page 58

**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 09-01 Source Information

Fire District: Toms Brook **Hydrant #:** 09-01

Address: 38 Cecelia St. (Behind address)

Long & Lat: 38.946553 -78.426507 **Source Type:** Pond

Roadway Surface: Paved **Turnaround available:** Yes

Owner: Ann Atkins **Phone #:** (540)436-3039

Draft Suction Sleeves: 2 **Draft Lift:** 11

Mapbook Page: 702 **Page Directions:** A-1

Layout distance from roadway to source access point: 20 feet

Source Size

Length: 139 **Width:** 93 **Depth:** 8



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 09-02 Source Information

Fire District: Toms Brook **Hydrant #:** 09-02

Address: 2204 Brook Creek Rd

Long & Lat: 38.968681 -78.462275 **Source Type:** Pond

Roadway Surface: Paved **Turnaround available:** No

Owner: Diane Jordan **Phone #:** 1(540)436-9142

Draft Suction Sleeves: 1 **Draft Lift:** 8

Mapbook Page: 30 **Page Directions:** B-1

Layout distance from roadway to source access point: 0

Source Size

Length: 342 **Width:** 114 **Depth:** 10



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 12-01 Source Information

Fire District: Woodstock **Hydrant #:** 12-01

Address: 3066 Alonzaville Road

Long & Lat: 38.931367 -78.549929 **Source Type:** Pond

Roadway Surface: Paved **Turnaround available:** Yes

Owner: Wilson Burke **Phone #:** 1(540)459-2006

Draft Suction Sleeves: 2 **Draft Lift:** 3

Mapbook Page: 38 **Page Directions:** C-3

Layout distance from roadway to source access point: 0

Source Size

Length: 153 **Width:** 60 **Depth:** 5



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 12-02 Source Information

Fire District: Woodstock **Hydrant #:** 12-02

Address: Stagecoach Rd @ Boat Landing

Long & Lat: 38.875762 -78.473045 **Source Type:** River

Roadway Surface: Gravel **Turnaround available:** Yes

Owner: Leisure Point Properties Donnie Coffman **Phone #:** (540) 459-2013

Draft Suction Sleeves: 2 **Draft Lift:** 11

Mapbook Page: 59 **Page Directions:** D-5

Layout distance from roadway to source access point: 180 feet

Source Size

Length: _____ **Width:** 50 **Depth:** 10



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 12-03 Source Information

Fire District: Woodstock **Hydrant #:** 12-03

Address: 1193 Coffmantown Rd

Long & Lat: 38.890063 -78.587305 **Source Type:** Pond

Roadway Surface: Gravel **Turnaround available:** Yes

Owner: _____ **Phone #:** _____

Draft Suction Sleeves: 2 **Draft Lift:** 8

Mapbook Page: 58 **Page Directions:** A-5

Layout distance from roadway to source access point: 200

Source Size

Length: _____ **Width:** _____ **Depth:** _____



Shenandoah County Department of Fire and Rescue Dry Hydrant Form

DH 12-04 Source Information

Fire District: Woodstock Hydrant #: 12-04

Address: 95 Kibo Court

Long & Lat: 38.944391 -78.528688 Source Type: Pond

Roadway Surface: Gravel Turnaround available: Yes

Owner: _____ Phone #: _____

Draft Suction Sleeves: 1 Draft Lift: 10

Map Book Page: 38-39 Page Directions: _____

Layout distance from roadway to source access point: 400

Source Size

Length: 20 Width: 25 Depth: 5



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 12-05 Source Information

Fire District: Woodstock **Hydrant #:** 12-05

Address: 6760 Back Road

Long & Lat: 28.931623 -78.532406 **Source Type:** Pond

Roadway Surface: Gravel **Turnaround available:**
No

Owner: Tammy Griffin **Phone #:** (540) 459-3438

Draft Suction Sleeves: 1 **Draft Lift:** 6

Mapbook Page: 38 **Page Directions:** C-5

Layout distance from roadway to source access point: 500 feet

Source Size

Length: 100 **Width:** 100 **Depth:** 5



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 13-01 Source Information

Fire District: Conicville **Hydrant #:** 13-01

Address: Across from 1590 Miller Road

Long & Lat: 38.862851 -78.732428 **Source Type:** Pond

Roadway Surface: Paved **Turnaround available:** Yes

Owner: _____ **Phone #:** _____

Draft Suction Sleeves: 1 **Draft Lift:** 5

Mapbook Page: 64 **Page Directions:** A-6

Layout distance from roadway to source access point: 0

Source Size

Length: 100 **Width:** 50 **Depth:** 8



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 13-02 Source Information

Fire District: Conieville **Hydrant #:** 13-02

Address: 618 Miller Rd

Long & Lat: 38.51727 -78.44954 **Source Type:** Pond

Roadway Surface: Paved **Turnaround available:**
Yes

Owner: _____ **Phone #:** _____

Draft Suction Sleeves: 1 **Draft Lift:** 10

Mapbook Page: 64 **Page Directions:** A-5

Layout distance from roadway to source access point: 25 feet

Source Size

Length: 30 **Width:** 30 **Depth:** 4



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 13-03 Source Information

Fire District: Conieville **Hydrant #:** 13-03

Address: 2240 Pepper Road

Long & Lat: 38.820675 -78.705109 **Source Type:** Pond

Roadway Surface: Paved **Turnaround available:**
Yes

Owner: _____ **Phone #:** _____

Draft Suction Sleeves: 1 **Draft Lift:** 5

Mapbook Page: 76 **Page Directions:** C-3

Layout distance from roadway to source access point: 5 feet

Source Size

Length: 70 **Width:** 30 **Depth:** 5



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 13-04 Source Information

Fire District: Conieville **Hydrant #:** 13-04

Address: Across from 11045 Senedo Road

Long & Lat: 38.793145 -78.726504 **Source Type:** Pond

Roadway Surface: Gravel **Turnaround available:** Yes

Owner: Ashley Sears **Phone #:** _____

Draft Suction Sleeves: 1 **Draft Lift:** 10

Mapbook Page: 86 **Page Directions:** C-1

Layout distance from roadway to source access point: 50 feet

Source Size

Length: 50 **Width:** 50 **Depth:** 10



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 13-05 - Source Information

Fire District: Conicville **Hydrant #:** 13-05

Address: 48 Hillside Acres Lane

Long & Lat: 38.784893 -78.732219 **Source Type:**
Pond

Roadway Surface: Gravel **Turnaround available:**
Yes

Owner: Kipp Painter **Phone #:** _____

Draft Suction Sleeves: 1 **Draft Lift:** 12

Mapbook Page: 95 **Page Directions:** A-6

Layout distance from roadway to source access point: 100 feet

Source Size

Length: 75 **Width:** 40 **Depth:** 5



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 13-07 Source Information

Fire District: Conicville **Hydrant #:** 13-07

Address: 763 Conicville Road

Long & Lat: 38.827297 -78.677153 **Source Type:** Reservior

Roadway Surface: Gravel **Turnaround available:**
Yes

Owner: Conicville VFD **Phone #:** (540)477-2787

Draft Suction Sleeves: 1 **Draft Lift:** 10

Mapbook Page: 76 **Page Directions:** B-6

Layout distance from roadway to source access point: 0

Source Size

Length: _____ **Width:** _____ **Depth:** _____



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 13-08 Source Information

Fire District: Conieville **Hydrant #:** 13-08

Address: 10727 Senedo Road

Long & Lat: 38.788992 -78.730818 **Source Type:** Pond

Roadway Surface: Gravel **Turnaround available:** No

Owner: Katrina Gochenour **Phone #:** _____


Draft Suction Sleeves: 1 **Draft Lift:** 12

Mapbook Page: 85 **Page Directions:** D-6

Layout distance from roadway to source access point: 100 feet

Source Size

Length: 30 **Width:** 60 **Depth:** 5



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 14-01 Source Information

Fire District: Fort Valley **Hydrant #:** 14-01

Address: 2325 Boyer Road

Long & Lat: 38.53337 -78.23713 **Source Type:**
Pond

Roadway Surface: Gravel **Turnaround available:** Yes

Owner: Steve Adams **Phone #:** (540) 933-6282

Draft Suction Sleeves: 1 **Draft Lift:** 4

Mapbook Page: 63 **Page Directions:** A&B 2&3

Layout distance from roadway to source access point: 5

Source Size

Length: 122 **Width:** 40 **Depth:** 6

Located across from address, connections are 6" as well as 4.5". Marked with reflective red and white reflective tape.



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 14-02 Source Information

Fire District: Fort Valley **Hydrant #:** 14-02

Address: 1140 Hickory Lane

Long & Lat: 38.44946 -78.30844 **Source Type:** Pond

Roadway Surface: Gravel **Turnaround available:** Yes

Owner: Norman Bouchard **Phone #:** (540) 933-6526

Draft Suction Sleeves: 1 **Draft Lift:** 6

Mapbook Page: 109 **Page Directions:** B-1

Layout distance from roadway to source access point: 3

Source Size

Length: 100 **Width:** 80 **Depth:** 6

Located on left side of the road when turning off of South Fort Valley Road, hose fitting is 4.5" marked with red and white reflective tape.



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 14-03 Source Information

Fire District: Fort Valley **Hydrant #:** 14-03

Address: Intersection of Mine Mountain Lane/ Mine Shaft Lane (Shawnee Lake)

Long & Lat: 38.53337 -78.23713 **Source Type:** Pond

Roadway Surface: Gravel **Turnaround available:** Yes

Owner: Mine Mountain HOA **Phone #:**

Draft Suction Sleeves: 2 **Draft Lift:** 4

Mapbook Page: 60 **Page Directions:** A-1

Layout distance from roadway to source access point: 5

Source Size

Length: 122 **Width:** 60 **Depth:** 6

Pond is fed by nearby stream, connections are 6" as well as 4.5" , marked with red a white reflective tape also has reflective blue dry hydrant sign.



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 14-04 Source Information

Fire District: Fort Valley **Hydrant #:** 14-04

Address: 1455 Seven Fountains Road

Long & Lat: 38.843074 - 78.399032 **Source Type:** Pond

Roadway Surface: Gravel **Turnaround available:** Yes

Owner: Damon Andrew **Phone #:** _____

Draft Suction Sleeves: 2 **Draft Lift:** 8

Mapbook Page: 71 **Page Directions:** _____

Layout distance from roadway to source access point: 225 feet

Source Size

Length: 258 **Width:** 122 **Depth:** 10



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 14-05 Source Information

Fire District: Fort Valley **Hydrant #:** 14-05

Address: 120 Blackhawk Lane

Long & Lat: 38.762766 - 78.499370 **Source Type:** Pond

Roadway Surface: Gravel **Turnaround available:** Yes

Owner: Robert Pratt **Phone #:** _____

Draft Suction Sleeves: 2 **Draft Lift:** 10

Mapbook Page: 100 **Page Directions:** _____

Layout distance from roadway to source access point: 10

Source Size

Length: 120 **Width:** 65 **Depth:** 6

Hydrant is located off of second entrance to Blackhawk Lane



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 14-06 Source Information

Fire District: Fort Valley **Hydrant #:** 14-06

Address: Passage Creek Bridge on Ramsey Road

Long & Lat: 38.889955 -78.376797 **Source Type:** Stream

Roadway Surface: Gravel **Turnaround available:** Yes

Owner: _____ **Phone #:** _____

Draft Suction Sleeves: 2 **Draft Lift:** 10

Mapbook Page: 61 **Page Directions:** _____

Layout distance from roadway to source access point: 50

Source Size

Length: _____ **Width:** _____ **Depth:** _____

Hydrant is to the left of bridge on Ramsey Road



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 14-07 Source Information

Fire District: Fort Valley **Hydrant #:** 14-07

Address: Across From 796 Privet Lane

Long & Lat: 38.839250 - 78.437590 **Source Type:** Pond

Roadway Surface: Gravel **Turnaround available:**
Yes

Owner: Jim & Susan Medley **Phone #:** (609) 577-7962

Draft Suction Sleeves: 2 **Draft Lift:** 10

Mapbook Page: 81 **Page Directions:** _____

Layout distance from roadway to source access point: 600 feet

Source Size

Length: 194 **Width:** 70 **Depth:** 10



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 14-08 Source Information

Fire District: Fort Valley **Hydrant #:** 14-08

Address: 10 Boyer Road (Across from 75 Boyer Rd)

Long & Lat: 38.865629 - 78.407382 **Source Type:** Pond/Lake

Roadway Surface: Gravel **Turnaround available:** Yes

Owner: Ma Jackie Z **Phone #:** _____

Draft Suction Sleeves: 2 **Draft Lift:** 10

Mapbook Page: 71 **Page Directions:** _____

Layout distance from roadway to source access point: 50 feet

Source Size

Length: 352 **Width:** 106 **Depth:** 10



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 14-09 Source Information

Fire District: Fort Valley **Hydrant #:** 14-09

Address: 9881 Fort Valley Rd

Long & Lat: 78.388445 - 38.875950 **Source Type:** Pond/Lake

Roadway Surface: Gravel **Turnaround available:** Yes

Owner: Carl and Diane Peratt **Phone #:** _____

Draft Suction Sleeves: 2 **Draft Lift:** 10

Mapbook Page: 61 **Page Directions:** _____

Layout distance from roadway to source access point: 50 feet

Source Size

Length: 352 **Width:** 106 **Depth:** 10



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 18-01 Source Information

Fire District: Orkney Springs **Hydrant #:** 18-01

Address: 922 Orkney Grade

Long & Lat: 38.805352 - 78.801611 **Source Type:** Concrete Vault – Rain Water

Roadway Surface: Concrete **Turnaround available:** Yes

Owner: Orkney Springs Fire and Rescue **Phone #:** 540-856-2990

Draft Suction Sleeves: 2 **Draft Lift:** 10

Mapbook Page: 814 **Page Directions:** _____

Layout distance from roadway to source access point: 10 feet

Source Size

Length: 352 **Width:** 106 **Depth:** 10



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 18-02 Source Information

Fire District: Orkney Springs **Hydrant #:** 18-02

Address: 3183 Alum Springs Rd.

Long & Lat: 38.835182 -78.776661 **Source Type:** Pond

Roadway Surface: Gravel **Turnaround available:** Yes

Owner: James and Barbara Fagan **Phone #:** _____

Draft Suction Sleeves: 2 **Draft Lift:** 10

Mapbook Page: 75 **Page Directions:** _____

Layout distance from roadway to source access point: 25 feet

Source Size

Length: 352 **Width:** 106 **Depth:** 10



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 18-03 Source Information

Fire District: Orkney Springs **Hydrant #:** 18-03

Address: Intersection of Orkney Grade and Holly Ridge Rd

Long & Lat: 38.790830 - 78.763795 **Source Type:** Pond

Roadway Surface: Gravel **Turnaround available:** Yes

Owner: Shenandoah Ski and Hunt **Phone #:** _____

Draft Suction Sleeves: 1 **Draft Lift:** 15

Mapbook Page: 85 **Page Directions:** _____

Layout distance from roadway to source access point: 25 feet

Source Size

Length: 352 **Width:** 106 **Depth:** 10



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 23-01 Source Information

Fire District: New Market **Hydrant #:** 23-01

Address: 9 Foothills Lane

Long & Lat: 38.640762 -78.642107 **Source Type:** Pond

Roadway Surface: Gravel **Turnaround available:** Yes

Owner: Sundance Retreat Homeowners Assoc. Larry Meyers **Phone #:** (540) 740-9205

Draft Suction Sleeves: 1 **Draft Lift:** 4 +

Mapbook Page: 128 **Page Directions:** B-4

Layout distance from roadway to source access point: 700

Source Size

Length: 125 **Width:** 100 **Depth:** 18



**Shenandoah County Department of Fire and Rescue
Dry Hydrant Form**

DH 51-01 Source Information

Fire District: Strasburg **Hydrant #:** 51-01

Address: 2 Battlefield Road

Long & Lat: 39.004969 - 78.440902 **Source Type:** Pond

Roadway Surface: Gravel **Turnaround available:**
Yes

Owner: John Stevenson **Phone #:** _____

Draft Suction Sleeves: 2 **Draft Lift:** 5

Mapbook Page: 23 **Page Directions:** A-3

Layout distance from roadway to source access point: 270 feet

Source Size

Length: 180 **Width:** 185 **Depth:** 6

